

Classification Report

Number	21-002821-PR01 (NW-A01-02-en-01)
Owner	IALONET - AFOI KONTOU P.C. Kriezi 55 19300 Aspropyrgos Greece
Product	Tripple sliding projecting side-hung casement
Designation	System: FFW55 Shipping name: FFW55 THERMO
Details	Manufacturer IALONET - AFOI KONTOU P.C., - Aspropyrgos; Material Aluminium system with thermal break; Type of opening Sliding-turn; Opening direction Active leaf right side; Overall dimensions (W x H) 3067 mm x 2600 mm
Special features	Test sequence. Internal drainage connection necessary. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately. Water drainage of rebate over the lower connection joint to the floor, which must be carried out accordingly.

Result **)

Air permeability according to EN 12207:2016-12



Class: 3

Resistance to wind load according to EN 12210:2016-03



Class: B2

Watertightness according to EN 12208:1999-11



Class: 7A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

15.02.2022



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-002821-PR01 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 755-80E78